























COLUMN SCHEDULE										
COL. NOS.		C1			C2			C3		
SECOND FLOOR LVL. TO TERRACE LVL.	SIZE	1'-4"X2'-6"			1'-0"X2'-0"			1'-2"X2'-0"		
	MIX	M25			M25			M25		
	MAIN REINF.	20-16Φ			14-16Φ			4-20Φ(a)+ 10-16Φ		
	STRPS.	Φ8@100&Φ8@150c/c 1SET OF 5 STRPS.			Φ8@100&Φ8@150c/c 1SET OF 4 STRPS.					
FIRST FLOOR LVL. TO SECOND FLOOR LVL.	SIZE	1'-4"X2'-6"			1'-0"X2'-0"			1'-2"X2'-0"		
	MIX	M25			M25			M25		
	MAIN REINF.	8-20Φ(a)+ 12-16Φ			6-20Φ(a)+ 8-16Φ			10-20Φ(a)+ 4-16Φ		
	STRPS.	Φ8@100&Φ8@150c/c 1SET OF 5 STRPS.			Φ8@100&Φ8@150c/c 1SET OF 4 STRPS.					
FOUNDATION TO FIRST FLOOR LVL.	SIZE	1'-4"X2'-6"			1'-0"X2'-0"			1'-2"X2'-0"		
	MIX	M25			M25			M25		
	MAIN REINF.	20-20Φ			14-20Φ			14-20Φ		
	STRPS.	Φ8@100&Φ8@150c/c 1SET OF 5 STRPS.			Φ8@100&Φ8@150c/c 1SET OF 4 STRPS.					

COLUMN SCHEDULE										
COL. NOS.		C4			C5			C6		
SECOND FLOOR LVL. TO TERRACE LVL.	SIZE	1'-0"X2'-0"			1'-4"X2'-6"			1'-4"X2'-6"		
	MIX	M25			M25			M25		
	MAIN REINF.	14-16ϕ			8-20ϕ(a)+ 12-16ϕ			20-20ϕ		
	STRPS.	ϕ8@100&ϕ8@150c/c 1SET OF 4 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.		
FIRST FLOOR LVL. TO SECOND FLOOR LVL.	SIZE	1'-0"X2'-0"			1'-4"X2'-6"			1'-4"X2'-6"		
	MIX	M25			M25			M25		
	MAIN REINF.	14-16ϕ			20-20ϕ			8-25ϕ(a)+ 12-20ϕ		
	STRPS.	ϕ8@100&ϕ8@150c/c 1SET OF 4 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.		
FOUNDATION TO FIRST FLOOR LVL.	SIZE	1'-0"X2'-0"			1'-4"X2'-6"			1'-4"X2'-6"		
	MIX	M25			M25			M25		
	MAIN REINF.	10-20ϕ(a)+ 4-16ϕ			8-25ϕ(a)+ 12-20ϕ			16-25ϕ(a)+ 4-20ϕ		
	STRPS.	ϕ8@100&ϕ8@150c/c 1SET OF 4 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.			ϕ8@100&ϕ8@150c/c 1SET OF 5 STRPS.		

COLUMN SCHEDULE				
COL. NOS.		C7		
FOUNDATION TO TILL GROUND FLOOR	SIZE	0'-9"X0'-9"		
	MIX	M20		
	MAIN REINF.	4-16Ø(a)+ 2-12Ø		
	STRPS.	Ø8@100&Ø8@150c/c 1SET OF 2 STRPS.		

